ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

CERTIFICATE

No. Z2 104598 0004 Rev. 00

Holder of Certificate: **Mysolar Manufacturing (Shanghai)Co.,Ltd.**
Room J8097, Bldg 2,
No. 4268, Zhennan Rd
Jiading District
201800 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:

Safety tested · Production monitored · TÜV SÜD · IEC 61730 · IEC 61215 · Photovoltaics · Anti-PID · System voltage durability · PPP 58042

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Poly-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 701261906204-00

Valid until: 2024-04-15

Date, 2019-05-28 (Zhulin Zhang)

A4 / 07.17

TÜV®

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

Product Service

CERTIFICATE

No. Z2 104598 0004 Rev. 00

Model(s):

MSxxxP-S, xxx=205 to 350 in step of 5
xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class :	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL 790
PID test condition:	-1500 V DC, 85 °C, 85 % RH, 96h

PID testing method is according to IEC TS 62804-1:2015.

Tested according to:

IEC 61215-1(ed.1)
IEC 61215-1-1(ed.1)
IEC 61215-2(ed.1)
IEC 61730-1(ed.2)
IEC 61730-2(ed.2)
PPP 58042B:2015

Production Facility(ies):

054757

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

A4 / 07.17

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany