



CERTIFICATE

No. Z2 104598 0008 Rev. 00

Holder of Certificate: Mysolar Manufacturing (Shanghai)Co.,Ltd.

Room J8097, Bldg 2, No. 4268, Zhennan Rd Jiading District 201800 Shanghai

PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Poly-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

701261906208-00

Valid until:

2024-06-12

Date,

2019-07-01

(Zhulin Zhang)

gris

TÜV®

CERTIFICATE

No. Z2 104598 0008 Rev. 00

Model(s): MSxxxP-S, xxx=90 to 350 in step of 5,

MSxxxP-S, xxx=70 to 80 in step of 5, MSxxxP-S, xxx=55 to 60 in step of 5, MSxxxP-S, xxx=35 to 40 in step of 5,

MSxxxP-S, xxx=30, MSxxxP-S, xxx=10

xxx is standing for rated output power at STC

Parameters: Construction:

Framed, with Junction box, Cable and Connectors.

Safety Class:

Class II

Maximum System Voltage:

1500 V DC

Fire Safety Class:

Class C according to UL 790

Severity of salt mist test: Level 6

Tested according to:

IEC 61215-1(ed.1) IEC 61215-1-1(ed.1) IEC 61215-2(ed.1) IEC 61730-1(ed.2) IEC 61730-2(ed.2) IEC 61701(ed.2)

Production Facility(ies):

054757

